



Maintenance recommendation Neles™ ValvGuard™ VG9000 – intelligent safety solenoid

Equipment	Element	Recommended maintenance Once a year	Recommended maintenance 5-6 years	Recommended maintenance 12 years
VG9000	Complete device	Visual inspection of condition: air leakages, linkage and mounting bracket, cover, electric conduit, loop test	Download and analyse diagnostics Calibrate, reset counters (if parts replaced)	Replace (12 years useful lifetime of the unit)
VG9000	Spool valve	No action	Check*	
VG9000	Prestage	No action	Check*	
VG9000	RCI	No action	No action	Replace (12 years useful lifetime of the unit)

* Replace if worn out/damaged

VG9000 maintenance can be done by Valmet certified service personnel only!



Operational
benefits:



Improved
plant
availability



Optimized
performance



Ensured
quality



Improved
safety